



United States Department of the Interior

U.S. GEOLOGICAL SURVEY
Reston, Virginia 20192

REPORT OF CALIBRATION of Aerial Mapping Camera

July 10, 1997

Camera type:	Wild RC30*	Camera serial no.:	5220
Lens type:	Wild Universal Aviogon /4-S	Lens serial no.:	13231
Nominal focal length:	153 mm	Maximum aperture:	f/4
		Test aperture:	f/4

Submitted by: Air Photographics, Inc.
Martinsburg, West Virginia

Reference: Air Photographics, Inc., purchase
order No. 5116, dated July 8, 1997.

These measurements were made on Kodak Micro-flat glass plates, 0.25 inch thick, with spectroscopic emulsion type 157-01 Panchromatic, developed in D-19 at 68° F for 3 minutes with continuous agitation. These photographic plates were exposed on a multicollimator camera calibrator using a white light source rated at approximately 5200K.

I. Calibrated Focal Length: 153.041 mm

II. Lens Distortion

Field angle:	7.5°	15°	22.7°	30°	35°	40°
Symmetric radial (um)	-1	-1	-1	0	1	1
Decentering (um)	0	0	1	2	2	3

Symmetric radial
distortion parameters

Decentering
distortion parameters

Calibrated
principal point

$$\begin{aligned} K_0 &= 0.4153 \times 10^{-4} \\ K_1 &= -0.8002 \times 10^{-8} \\ K_2 &= 0.3080 \times 10^{-12} \\ K_3 &= 0.0000 \\ K_4 &= 0.0000 \end{aligned}$$

$$\begin{aligned} P_1 &= -0.6697 \times 10^{-7} \\ P_2 &= 0.1865 \times 10^{-6} \\ P_3 &= 0.0000 \\ P_4 &= 0.0000 \end{aligned}$$

$$\begin{aligned} x_p &= 0.004 \text{ mm} \\ y_p &= 0.001 \text{ mm} \end{aligned}$$

The values and parameters for Calibrated Focal Length (CFL), Symmetric Radial Distortion (K_0, K_1, K_2, K_3, K_4), Decentering Distortion (P_1, P_2, P_3, P_4), and Calibrated Principal Point [point of symmetry] (x_p, y_p) were determined through a least-squares Simultaneous Multiframe Analytical Calibration (SMAC) adjustment. The x and y-coordinate measurements utilized in the adjustment of the above parameters have a standard deviation (σ) of ± 3 microns.

* Equipped with Forward Motion Compensation

III. Lens Resolving Power in cycles/mm

Area-weighted average resolution: 102

Field angle:	0°	7.5°	15°	22.7°	30°	35°	40°
Radial Lines	134	134	113	113	113	80	95
Tangential lines	134	134	113	113	113	80	80

The resolving power is obtained by photographing a series of test bars and examining the resultant image with appropriate magnification to find the spatial frequency of the finest pattern in which the bars can be counted with reasonable confidence. The series of patterns has spatial frequencies from 5 to 268 cycles/mm in a geometric series having a ratio of the 4th root of 2. Radial lines are parallel to a radius from the center of the field, and tangential lines are perpendicular to a radius.

IV. Filter Parallelism

The two surfaces of the Wild 420 Pan No. 6496 and the 525 Pan No. 6947 filters accompanying this camera are within 10 seconds of being parallel. The 525 filter was used for the calibration.

V. Shutter Calibration

<u>Indicated exposure time</u>	<u>Effective exposure time</u>	<u>Efficiency</u>
1/125	8.00 ms = 1/125 s	81%
1/250	4.20 ms = 1/240 s	81%
1/500	2.10 ms = 1/475 s	81%
1/1000	1.05 ms = 1/950 s	81%


The effective exposure times were determined with the lens at aperture f/4. The method is considered accurate within 3 percent. The technique used is Method I described in American National Standard PH3.48-1972(R1978).

VI. Film Platen

The film platen mounted in Wild RC30 drive unit No. 5220-589 does not depart from a true plane by more than 13 um (0.0005 in).

This camera is equipped with a platen identification marker that will register "589" in the data strip area for each exposure.

VII. Principal Points and Fiducial Coordinates



Positions of all points are referenced to the principal point of autocollimation (PPA) as origin. The diagram indicates the orientation of the reference points when the camera is viewed from the back, or a contact positive with the emulsion up. The data strip is to the left.

	<u>X coordinate</u>	<u>Y coordinate</u>
Indicated principal point, corner fiducials	0.006 mm	0.002 mm
Indicated principal point, midside fiducials	0.010	0.000
Principal point of autocollimation (PPA)	0.0	0.0
Calibrated principal point (pt. of sym.) x_p, y_p	0.004	0.001

Fiducial Marks

1	-105.993 mm	-105.998 mm
2	106.006	106.001
3	-105.992	105.995
4	106.012	-105.998
5	-112.003	-0.002
6	112.011	0.002
7	0.009	112.004
8	0.010	-111.993

VIII. Distances Between Fiducial Marks

Corner fiducials (diagonals)

1-2: 299.812 mm 3-4: 299.811 mm

Lines joining these markers intersect at an angle of 90° 00' 05"

Midside fiducials

5-6: 224.014 mm 7-8: 223.998 mm

Lines joining these markers intersect at an angle of 89° 59' 58"

Corner fiducials (perimeter)

1-3: 211.993 mm 2-3: 211.998 mm

1-4: 212.005 mm 2-4: 211.999 mm

The method of measuring these distances is considered accurate within 0.003 mm

Note: For GPS applications, the nominal entrance pupil distance from the focal plane is 283 mm.


IX. Stereomodel Flatness

FMC Drive unit No.: 5220-589

Base/Height ratio: 0.6

Platen ID: 589

Maximum angle of field tested: 40°



The values shown on the diagram are the average departures from flatness (at negative scale) for two computer-simulated stereomodels based on comparator measurements on contact glass (Kodak Micro-flat) diapositives made from Kodak 2405 film exposures. These measurements are considered accurate within 5 um.

X. System Resolving Power on film in cycles/mm

Area-weighted average resolution:	48						Film:	Type 2405
Field angle:	0°	7.5°	15°	22.7°	30°	35°	40°	
Radial Lines	67	57	57	57	48	48	48	
Tangential lines	67	57	48	48	48	40	40	

This aerial mapping camera calibration report supersedes the previously issued USGS Report No. OSL/2011, dated July 14, 1994.

Bradish F. Johnson

Bradish F. Johnson
Chief, Optical Science Laboratory
National Mapping Division